

GAS PIPING PRESSURE AND LEAKAGE TEST

Company Name _____

I _____ certify that I have tested the gas piping system at
(Licensed Pipefitter by the City of Watertown)

_____, the results of which are tabulated below.
(Address of gas service installation)

Size of pipe: _____ Length of pipe: _____ Type of pipe: _____

Size of pipe: _____ Length of pipe: _____ Type of pipe: _____

Size of pipe: _____ Length of pipe: _____ Type of pipe: _____

Air Test Results

TEST DATE	TIME	GAUGE PRESSURE	READ BY	REMARKS

CGI or Bubble Test results (only applies for equipment replacements)

TEST DATE	TIME	CGI OR BUBBLE TEST	READ BY	REMARKS

I further certify that the piping described above is free of any leaks, in accordance with the Watertown City Code and the National Fuel Code's "Specifications and Requirements for Gas Installations", and adequate to service gas to the appliances installed at the above-mentioned location.

Signature Date

Notes:

- 1) A minimum of two (2) readings shall be taken not less than 30 minutes apart. Test pressures shall be in accordance with the National Fuel Code.
- 2) Submitting this form does not constitute a meter order.
- 3) The results of this test shall be deemed valid for a period of two (2) years from the date of the test barring any changes to the piping system.
- 4) Before activating the service, an initial inspection by Watertown Municipal Utilities will be done at no charge. The person(s) requesting the inspection must be present at the time of inspection.
- 5) The gas service will not be activated until inspected and passed.
- 6) Submitting this form does not relieve the contractor from any liability for the installation. Installation must comply with the manufacturer's specifications and in accordance with the National Fuel Code and City Codes.